



Legenda

- Conducta incalzire tur -PEX
 - Conducta incalzire retur -PEX
 - Conducta incalzire tur cupru
 - - - Conducta incalzire retur cupru
 - Robinet cu obturator sferic
 - - Pn 6 bar, Tmax 100°C-apa incalzire
- $\phi 20$
 $Q=2090w$
 $P=150mm$
 $L=100m$
- Pardoseala incalzitoare, $Q=2090w$, 45/40, avand conductata cu $De = 20 mm$, montata in circuit cu pasul de 150 mm, in lungime de 100 m.

	Verificator / Expert:	Nume:	Semnatura:	Cerinta:	Referat / Expertiza Nr. / Data:
			S.C. PROIECT BIHOR S.A. RO-410067 - Oradea Str. Generala Haghima, Nr. 23 ORC Nr. J 05/200/1991 CLJ P07119 Tel.: 40-238411-23-30, 41-43-81, 41-83-82 Fax: 40-238411-83-80 e-mail: proiect.bihor@proiect.ro http://www.proiect-bihor.ro		
	Beneficiar: S.C. O.T.L. S.A. Lucrare: STATIE DE TRANSBORDARE (AUTOGARA) B-DUL DECEBAL - INT. CALEA ARADULUI, MUN. ORADEA, JUD. BIHOR		Contr. Nr.: 15933/259/2012 Faza: D.T.A.C.		
	Sef proiect: arh. Hermann A. Kriestian Proiectat: Ing. Puscas Marius Verificat: Ing. Pacurar Ioan	Scara: 1:50 Data: Feb. 2013	PLAN STATIE TRANSBORDARE (AUTOGARA) INSTALATII INCALZIRE		